

ATAL INCUBATION CENTRE - PEC FOUNDATION

Proc/AIC-PECF/2024/090

Dated: **06-05-2024**

Call for Quotation

Call for Quotation for the supply & Installation of 7.5KVA/180VDC Online UPS system with Exide Tubular Battery 12V/150AH – 15 nos for FAB LAB Unit at AICPECF.

Quotation is invited by Atal Incubation Centre-Pondicherry Engineering College Foundation (AIC-PECF) from all intending suppliers(s) for supply & Installation of 7.5KVA/180VDC Online UPS system with Exide Tubular Battery 12V/150AH – 15 nos for FAB LAB Unit at AICPECF and Buyback value for Used/Old SMF Batteries - 24nos in AICPECF.

- i. The Technical specifications of the items are furnished in Annex – 1 .
- ii. All the Quotations should be addressed to
ATAL INCUBATION CENTRE – PEC FOUNDATION
Puducherry Technological University Campus,
Pillichavady, Puducherry-605014.
- iii. All the quotations shall be signed and sealed by the competent authority of the supplier in the official letter head.
- iv. All the quotations shall be Emailed to coo@aicpecf.org and cc to ceo@aicpecf.org
- v. All the quotations shall be sent along with the data sheets of the equipment with make and specifications.
- vi. The quotations should reach on or before **17-05-2024** by **05.00 P.M.**

Chief Operating Officer
AIC-PECF

ATAL INCUBATION CENTRE - PEC FOUNDATION

Terms and Conditions

- 1) Minimum 3 year of warranty for Online UPS and 4 Years warranty for Tubular Batteries and Service Support for 5 years.
- 2) The rate quoted should be preferably inclusive all taxes / duties. otherwise the amount of taxes / duties should be mentioned separately, duly specifying the nature of tax / duty with the rate there of.
- 3) The supply should be FOR ATAL INCUBATION CENTRE – PEC FOUNDATION , PTU campus,Pillaichavady, Puducherry – 605 014.
- 4) You are responsible for the safe delivered of the stores at our organization.
- 5) No Insurance Charges will be payable by this organization.
- 6) All communication should be addressed to the Chief Executive Officer by designation and not by name.
- 7) Payment will be made by PFMS after the receipt of good in good condition and the bills with pre-receipted and stamped receipts.
- 8) Under no circumstances should the items be sent under freight to pay.
- 9) Goods not received in good condition and not according to specifications will be rejected outright.
- 10)Manufacturers/Suppliers name their trade mark and brand etc., should be mentioned in the bill.
- 11)Delivery period should be mentioned.
- 12)Quotation received after the due date shall be rejected and will not be considered.

ATAL INCUBATION CENTRE - PEC FOUNDATION

Annexure – 1

	ITEMS	REQUIREMENT (nos)
1	7.5KVA/180VDC IGBT Based Transformer Model APWM Technology Double Conversion 1P I/O Pure Sinewave Online UPS System	1nos

Specification :

Input DC Voltage	180V DC
Output AC Voltage	230V AC 1Phase
AC Frequency	50Hz
Waveform	Pure Sinusoidal
Load Power Factor	Unity PF
Harmonic Distortion	<3%
Over Load Protection	150%- 10 Seconds
Short Circuit Protection	YES
Display	Mains On, Inverter On, Low Battery Indication, Over Voltage, Low Voltage, Over Load, Input Voltage, Output Voltage
Alarm	Low Battery, Inverter Trip
Ambient Temperature	0-45 Dec C
Exide EL Tubular Battery – 150AH/12V	15 Nos.
Battery Rack	01 No.

ATAL INCUBATION CENTRE - PEC FOUNDATION

	ITEMS	Available Quantity (nos)	Value(inr)
2	Old Exide SMF Batteries 12V/ 120AH	24nos	